

Wasserwerk der Stadt Brakel

Tabelle gemessener Nitratwerte aller aktiven Brunnen

Probe entnommen am:	Wasserwerk	Chem. U. Amt PB	Ostheim	Sudheim	Hampenhäusen	Erkeln	Bökendorf	Hembsen	Gehrden	Riesel	Schmechten Brunnen	Schmechten Mischwasser	Bemerkungen
02.01.2006	X		40	24		45	45		34	40	45	43	
06.02.2006	X		38	24		46	46		34	42	44	41	
03.03.2006	X		38	27		48	46		36	43	42	42	
31.03.2006	X		39	27		47	42		32	42	41	40	
28.04.2006	X		39	27		43	45		29	40	40	41	
03.05.2006		X	37	26		41	43		34	40	37		
02.06.2006	X		36	26		40	44		33	38	32	37	
30.06.2006	X		36	25		39	43		32	32	37	34	
02.08.2006	X		34	28		38	44		33	34	37	35	
01.09.2006	X		38	27		40	45		33	34	42	38	
29.09.2006	X		38	26		41	44		31	34	44	39	
04.10.2006		X	38	25		41	45		31	34	25		
03.11.2006	X		37	28		42	-		30	33	41	38	Brunnenpumpe in Bökendorf defekt
04.12.2006	X		37	24		43	44		31	35	47	42	
29.12.2006	X		36	22		42	43		32	36	32	40	
02.02.2007	X		40	24		45	45		32	42	47	45	
02.03.2007	X		39	24		41	36		33	43	44	42	
30.03.2007	X		40	27		43	47		34	43	48	44	
02.05.2007	X		38	27		42	46		36	40	36	41	
23.05.2007		X	39	27		40	48		38	39	32		
01.06.2007	X		38	28		41	44		37	37	42	38	
29.06.2007	X		37	27		39	44		32	35	40	36	
01.08.2007	X		38	27		37	33		29	35	40	35	
Übersicht Nitrat-Statistik:	Max		47	42		55	51		56	54	63	49	
(seit 1997)	Min		33	21		34	33		26	29	16	34	
	Mittel		41	29		44	45		39	41	43	41	
	Messungen		144	144		147	152		150	155	153	67	Jahresniederschlag
	Mittel 2003		39	27		40	42		34	36	40	41	602 mm
	Mittel 2004		40	29		46	47		37	40	44	43	759 mm
	Mittel 2005		40	28		44	48		36	39	41	42	777 mm
	Mittel 2006		38	26		42	44		32	37	40	39	710 mm